

# ExCam® Series



T08 - Installation Manual



## Contents

<b>1</b>	<b>Introduction .....</b>	<b>4</b>
<b>2</b>	<b>Technical Data .....</b>	<b>4</b>
2.1	Parameters of the Explosion Protection .....	4
2.1.1	T08-VAx.x.x.x-X-X-X-X .....	4
2.1.2	T08-TNXCD-X-X-X-X .....	5
2.1.3	Conformity of Standards (Gas) .....	5
2.2	Electrical Parameters .....	5
2.2.1	Power Supply .....	5
2.2.2	Power and Temperatures .....	6
2.3	Other Technical Data .....	6
<b>3</b>	<b>General Safety Instructions .....</b>	<b>8</b>
<b>4</b>	<b>Application .....</b>	<b>10</b>
<b>5</b>	<b>Transportation and Storage .....</b>	<b>11</b>
<b>6</b>	<b>Commissioning .....</b>	<b>11</b>
6.1	Installation .....	11
6.1.1	Type T08-VAx.x.x.x .....	12
6.1.2	Type T08-TNXCD .....	13
6.2	Opening and closing of the unit .....	13
6.2.1	Type T08-VAx.x.x.x .....	13
6.2.2	Type T08-TNXCD .....	17
6.3	Electrical Connection and Commissioning .....	21
<b>7</b>	<b>Maintenance/ Modification .....</b>	<b>22</b>
<b>8</b>	<b>Reparation .....</b>	<b>22</b>
<b>9</b>	<b>Disposal/ Recycling .....</b>	<b>22</b>
<b>10</b>	<b>Drawings .....</b>	<b>22</b>
<b>11</b>	<b>Certificates .....</b>	<b>23</b>
11.1	EC – declaration of conformity .....	23
11.2	Manufacturer's declaration concerning the cable and cable entry points .....	24
11.3	EC-Type Examination Certificate .....	25
11.4	IECEx Certificate of Conformity .....	32
11.5	EAC-Ex Certification .....	40

## List of illustrations

Figure 10-1 T08-VAx.x.x.x mounting options.....	12
Figure 10-7 Opening of the ExCam T08-VAx.x.x.x.....	14
Figure 10-8 Disassembly of the countersunk head screw type T08-TNXCD .....	18
Figure 10-9 Opening of the cover flange type T08-TNXCD .....	19
Figure 10-10 Position of the O-Ring sealing type T08-TNXCD.....	19

## History of revisions

Product: T08 - ExCam® Series  
 Title: Ex Installation Manual of the ExCam Series  
 Doc.-Id. 140721-PT08BAU-SS-Ex Installation Manual rev.00.doc  
 Author: Steffen Seibert  
 Date: July 12, 2014  
 Revision Date: April 20, 2015

Rev.- Index	Date	Name	Comment	Authorization of the EX Supervisor
00	July 13, 2014	S. Seibert	Starting the document	
01	July 13, 2014	S. Seibert	Adding the declaration of confirmity	
02				
03	20.04.2015	S. Seibert	Correction and conclusions	
04	07.03.2017	S.Seibert	<ul style="list-style-type: none"> <li>- Adapting the Guideline 2014/34/EU</li> <li>- Adding the EAC-Ex Certificates</li> <li>- Ex-Warning for Dust</li> </ul>	 Digital unterschrieben von Steffen Seibert DN: cn=Steffen Seibert, o=SAMCON, ou= email=s.seibert@samcon.eu, c=DE Datum: 2017.03.07 10:58:04 +01'00'

# 1 Introduction

The ExCam Series (Type 08) is an electrical device. It is certified according to ATEX, IECEx and EAC-Ex as a pressure-resistant camera system to be used in gas and dust explosive areas as well as in mines susceptible to firedamp. At the front side, the camera systems dispose of a flange with a sight glass (optical adapter); on the rear side it is equipped with a flange which allows introducing one or more ex-certified cable and cable glands (CG) or sealing plugs, respectively. The T08 camera system is a very flexible system and can be used for various applications. The main usage is within hazardous areas in the chemical as well as petro-chemical industry, offshore plants, and mines susceptible to firedamp as well as biogas plants. The cameras are certified to be used in ex-zones 1, 2, 21, 22 including the explosion groups IIC (e.g. acetylene) and IIIC (conductive and flammable dusts). The Ex-d housings are available in different steel qualities due to which the housing's resistance towards extreme environmental conditions (sea water corrosion, high-acid environments etc.) is additionally extended.

Within the pressure-resistant enclosure, various camera modules and lenses reflecting different technical specifications are used. Accessory components such as PTC heating elements, miniature fans, NIR LED, lighting devices, mechanical components, and clamps made of aluminum, are optional. Criteria for selecting the camera module are, for example, transmission technology (digital or analog), control functions (IR cut filter, iris, focus), light sensitivity, angle of view, object distance, resolution, optical zoom range, frame rate, or transmission delay. Thermal imaging applications are possible as well. Therefore, the T08 range covers vast areas regarding industrial process observation as well as security surveillance – inside plants or outside.

## 2 Technical Data

## 2.1 Parameters of the Explosion Protection

### 2.1.1 T08-VAx.x.x.x-X-X-X-X



 II 2D (Zone 21 and 22)



CA 1 MZ



## Explosion protection (Gas):

Ex d IIC T6 Gb or

Ex d IIC T5 Gb or

Ex d IIB T6 Gb or

Ex d IIB T5 Gb or

#### Explosion protection (Dust):

Ex tb IIIC T80°C Db IP68 or

Ex tb IIIC T95°C Db IP68

## Explosion protection (Mining)

Ex d I Mb

## 2.1.2 T08-TNXCD-X-X-X-X

Identification marks according to directive 2014/34/EU:

 II 2G (zones 1 and 2)  
 II 2D (zones 21 and 22)

Explosion protection (Gas):

Ex d IIC T6 Gb or

Ex d IIB T6 Gb or

Explosion protection (Dust):

Ex tb IIIC T80°C Db IP66 or

Ex tb IIIC T80°C Db IP67 or

Ex tb IIIC T80°C Db IP68 or

## 2.1.3 Conformity of Standards (Gas)

Conformity of standards (Gas)

IEC 60079-0:2011, EN 60079-0:2012

IEC 60079-1:2008, EN 60079-1:2008

IEC 60079-11:2011, EN 60079-11:2012

IEC 60079-18:2009, EN 60079-18:2009

IEC 60079-28:2006/ ISH1:2014,

EN 60079-28:2007 (Beiblatt 1:2014-09)

GOST R IEC 60079-0-2011

GOST IEC 60079-1-2011

Conformity of standards (Dust)

IEC 60079-31:2008, EN 60079-31:2009

GOST R IEC 60079-31-2010

Notified body:

TÜV Rheinland (No. 0035)

ATEX:

TÜV 14 ATEX 7539X

IECEx:

IECEEx TUR14.0026X

EAC-Ex:

No. TC RU C-DE.MIO62.B.01921

Supplement/ Rev. Index:

01

Test Report ATEX:

557/Ex539.00/14

Test Report IECEx:

DE/TUR/ExTR14.0026/00

Quality Assessment Report:

DE/BVS/QAR14.0006/00

## 2.2 Electrical Parameters

### 2.2.1 Power Supply

These are maximum values as part of the approval. Please refer to the device-specific values in the respective user manual!

#### Type T08...:

Power Supply:

U<sub>IN</sub>: 12 ... 60 V DC or

U<sub>IN</sub>: 20 ... 240 V AC

## 2.2.2 Power and Temperatures

The below table 3-1 illustrates the maximum thermal supply input of all T08 ExCam housing types in relation to the ambient temperature and temperature classes. Performance limits have been evaluated during certification as well as during the T08 explosions protection concept and are obligatory.

T08-	T6 (85°C – 5K)				T5 (100°C – 15K)				
	T <sub>AMB</sub>				T <sub>AMB</sub>				
	40°C	50°C	60°C	70°C	40°C	50°C	60°C	70°C	75°C
VA1.1.x.x	17.4 W	13.0 W	8.7 W	4.3 W	19.6 W	15.2 W	10.9 W	6.5 W	4.3 W
VA1.1.x.x* <i>(coated)</i>	19.0 W	14.3 W	9.5 W	4.8 W	21.4 W	16.7 W	11.9 W	7.1 W	4.8 W
VA1.2.x.x	18.2 W	13.6 W	9.1 W	4.5 W	20.5 W	15.9 W	11.4 W	6.8 W	4.5 W
VA1.2.x.x* <i>(coated)</i>	21.1 W	15.8 W	10.5 W	5.3 W	23.7 W	18.4 W	13.2 W	7.9 W	5.3 W
VA2.1.x.x	22.2 W	16.7 W	11.1 W	5.6 W	25.0 W	19.4 W	13.9 W	8.3 W	5.6 W
VA2.1.x.x* <i>(coated)</i>	25.0 W	18.8 W	12.5 W	6.3 W	28.1 W	21.9 W	15.6 W	9.4 W	6.3 W
VA2.2.x.x	25.0 W	18.8 W	12.5 W	6.3 W	28.1 W	21.9 W	15.6 W	9.4 W	6.3 W
VA2.2.x.x* <i>(coated)</i>	26.7 W	20.0 W	13.3 W	6.7 W	30.0 W	23.3 W	16.7 W	10.0 W	6.7 W
TNXCD	57.1 W	42.9 W	28.6 W	n.A.	n.A				

## 2.3 Other Technical Data

Permitted temperature (storage)<sup>1</sup>:

T08-VAx.x.x.x

-60° C ... +85° C (T<sub>max</sub>)

T08-TNXCD

-20° C ... +80° C (T<sub>max</sub>) /with Viton O-ring

-30° C ... +80° C (T<sub>max</sub>) / with NBR 70 O-ring

-50° C ... +80° C (T<sub>max</sub>) / with VMQ- silicone O-ring

<sup>1</sup> Ex-relevant temperature limit (laboratory test: 336 h max. 90 % rest humidity / -65° C+5 K....105° C – 20 K safety margin)

Permitted ambient temperature: (during operation) <sup>2</sup>	<u>T08-VAx.x.x.x</u> -60° C ... +75 °C ( $T_{Amb}$ ) <u>T08-TNXCD</u> -20° C ... +60° C ( $T_{Amb}$ ) / with Viton O-ring -30° C ... +60° C ( $T_{Amb}$ ) / with NBR 70 O-ring -50° C ... +60° C ( $T_{Amb}$ ) / with VMQ-silicone O-ring
Max. surface temperature T6:	<u>T08-VAx.x.x.x/ T08-TNXCD</u> +80° C ( $T_{VA\_SUR\ T6}$ )
Max. surface temperature T5:	<u>T08-VAx.x.x.x</u> +85° C ( $T_{VA\_SUR\ T5}$ ) <u>T08-TNXCD</u> n.a. ( $T_{VA\_SUR\ T5}$ )
Functional temperature (MTBF) <sup>3</sup> :	<i>Please refer to the individual operating manual of the T08 series, e.g. ExCam IP135x, PM1145-L, IPQ6045, etc.!</i>
Protection level EN 60529/IEC 529:	<u>T08-VAx.x.x.x</u> IP68 (test condition: 24 h/ 3 m water column at 5° C). An additional mechanical protection against water jets is recommended  <u>T08-TNXCD</u> IP68 (permanent submission, standard) IP66 (Water jets, upon request)
Media resistance:	<i>Upon request</i>
Housing material:	Stainless steel (non-corrosive / EN 10027-2) WNr.: 1.4301 (X5CrNi18-10), AISI 304 WNr.: 1.4305 (X8CrNiS18-9), AISI 303 WNr.: 1.4401 (X5CrNiMo17-12-2), AISI 316 WNr.: 1.4404 (X2CrNiMo17-12-2), AISI 316L WNr.: 1.4571 (X6CrNiMoTi17-12-2), AISI 316Ti

<sup>2</sup> Ex-relevant „maximum“ ambient temperature limit during operation/ of performance limits

<sup>3</sup> Functional temperature range (MTBF) is always within the ex-relevant temperature limits and depends on the functional range of the camera model, or, if applicable, on additional mechanical and electrical installed components or installation/dimensioning of PTC heating element or the cooling system „SAMCool Jacket“ etc.

Fitting for the flameproof gap (cylinder)  
according to DIN ISO 286-1

T08-VA1.x :

$d_{f7}^{H8}$ , nominal diameter: 57mm,  
Tolerance: -60...-30 [ $\mu\text{m}$ ] – 0...+46 [ $\mu\text{m}$ ]  
Gap length:  $L_1=13.0$  [mm],  $L_2=16.2$  [mm]

T08-VA2.x :

$d_{f7}^{H8}$ , nominal diameter: 91mm,  
Tolerance: -71...-36 [ $\mu\text{m}$ ] – 0...+54 [ $\mu\text{m}$ ]  
Gap length:  $L_1=15.0$  [mm],  $L_2=23.0$  [mm]

Fitting for the flameproof gap  
TNXCD Dome Enclosure

T08-TNXCD:

Metric fine thread, M188\*1.5,  
quality 6H, supporting threads >5

Surface of the cylindrical fitting

Average surface finish according to DIN ISO 468

T08-VA1.x:  $R_a \leq 6.3 \mu\text{m}$

T08-VA2.x:  $R_a \leq 6.3 \mu\text{m}$

### 3 General Safety Instructions



#### Attention!

**Cameras of type ExCam are not suitable for use in zone 0 and zone 20. The temperature class and explosion group as stated on the type plate has to be observed. Alterations are not permitted. The camera is to be operated in sound condition and in the intended way**



#### Attention!

**Only original parts of SAMCON Prozessleittechnik GmbH may be used for repairs. Repairs concerning the explosion protection may only be carried out in accordance with the nationally applied regulations and by SAMCON Prozessleittechnik GmbH.**



#### Attention!

**External heat and/ or cooling sources are to be taken into account during the setting up. The permissible temperature range has to be observed.**



**Attention!**

**When using the ExCam in the mining sector with a "high" risk of mechanical danger, it is mandatory to protect the transparent parts (glass) of the device (accessory)!**



**Attention!**

**The instructions stated on the type and instruction plates have to be observed!**

**Camera modules with autofocus:**

**„WARNING – MAY NOT BE OPENED WHILE ENERGIZED.“**

**Adjustable camera modules or lenses:**

**„WARNING – MAY NOT BE OPENED IN HAZARD AREAS.“**

**Note: Depending on the zone classification, it might be necessary to obtain a work permit/clearance! When adjusting the camera settings potentially explosive atmosphere must be avoided by any means!**



**The scope of application for dust-zones with regard to temperature and dust deposits can be found in the national installation regulations.**

**Prior to start the cameras operation, the equipment has to be checked according to the instructions described in chapter Commissioning.**

**Always follow the national security and accident prevention regulations as well as the security advices described in the following of this user manual!**

## 4 Application

The cameras of the ExCam® series are designed and intended for the surveillance of plants as well as of processes at inner as well as outside areas within hazardous areas. The information stated on the type and on the instruction plate(s) has to be observed when using the camera. The information in chapter 3 and 4 has to be considered during operation. Without a written statement of Samcon Prozessleittechnik GmbH, the equipment may not be used for applications differing from the described and intended ones.

The T08 camera is suitable for applications in hazardous areas of zones 1 and 2 as well as zones 21 and 22 in accordance with EN 60079-10! The camera may only be used within the certified ignition protection type and temperature class.



### Attention!

**The instructions on the type and instruction plates have to be observed!**



### Attention!

**When using the ExCam in the mining sector with a „high“ risk of mechanical danger, suitable protection measures for the optical components are obligatory and have to be implemented (accessories)**



### Attention!

**The ExCam with a model key comprising TNXCD must not be used in the mining sector**



### Attention!

**The ExCam with a model key comprising TNXCD must only be used stationary (not hand-held)**

The used housing materials including the exterior metal parts are made of high-quality materials guaranteeing an application-specific corrosion protection and chemical resistance in "regular industrial climate".

## 5 Transportation and Storage

- Avoid impacts
- Check the equipment regarding possible damages at the packaging or the camera
- Store the camera in its original packaging and in a dry and weatherproof place until installation
- Avoid exposing the equipment to extreme heat or cold

## 6 Commissioning

### 6.1 Installation

The national regulations and accepted rules of technology are decisive for the installation and operation of the camera. Before installation, check the camera for possible damages to the housing and cables. Installation, electrical connection, and start-up should only be carried out by qualified personnel.



#### Attention!

**External heat and/or cold sources should be taken into account during installation. The permissible temperature range should not be exceeded**



#### Attention!

**The connecting cable has to have a minimum length of 1 meter. The connecting cable has to be laid shielded and in a protected manner**



#### Attention!

**When using the ExCam in the mining sector with a "high" risk of mechanical danger, it is mandatory to protect the transparent parts (glass) of the device (accessory)!**

### 6.1.1 Type T08-VAx.x.x.x

For the observation of plants and/or persons, the camera can be installed on a rotatable installation bracket (accessory). The pin which is laterally welded to the housing is intended for this purpose and disposes of a 6.5 mm or an 8.5 mm drilling. The wall mount bracket is available in different dimensions and may be installed in any position which is allowed by the four available drillings.




Figure 10-1 T08-VAx.x.x.x mounting options

For process observations, the camera can be mounted via a hinge attachment.

A thorough description and availability of the accessory components is included in the individual user manual.

### 6.1.2 Type T08-TNXCD

The PTZ camera type T08-TNXCD is mounted in a hanging manner (transparent dome copula facing downwards). For installing the dome camera at the wall, the six M8x1.25 threaded holes located at the cover flange and correspondingly at the wall mount bracket with L-profile (accessories) can be used. The installation at a ceiling can be realized via eyelets and a chain link construction. In addition, the housing has to be secured by the means of a "safety" for protecting heavy loads against dropping (included in the delivery scope).

## 6.2 Opening and closing of the unit

### 6.2.1 Type T08-VAx.x.x.x



**Attention! The pressure tight housing type T08-VAx.x.x.x may only be opened when allowed in the user manual of the camera, e.g. for manually adjusting Varifocal lenses, for the removal / exchange of the SD storage card, the exchange of the Gylon sealing etc.**



**Attention! Observe all warnings on the camera labels:**

**Camera modules with autofocus:**

**„WARNING – MAY NOT BE OPENED WHILE ENERGIZED“**

**Adjustable camera modules or lenses:**

**„WARNING – MAY NOT BE OPENED IN HAZARD AREAS“**

**NOTE: Depending on classification of the hazard area, a work permit/clearance has to be obtained. Prevent explosive atmospheres while assembling!**

The T08 ExCam Series may exclusively be opened due to functional aspects and when the applicable user manual explicitly allows it. For all other purposes, the explosion proof housing may only be opened and closed by authorized personnel of SAMCON Prozessleittechnik GmbH.

If, when looking through the borosilicate sight glass, a damage, irregularities, or alterations such as loose parts, discoloring or liquid inclusion (not water condensation!), are visible inside the ExCam, SAMCON Prozessleittechnik GmbH has to check the camera.

The following has to be observed:

Prior to opening the housing of the type T08-VAx.x.x.x it might be necessary to demount the hood or other accessory.

- The housing must only be opened on the rear flange of the cable and supply flange. It is not allowed to remove the optic-adapter in the front
- The following screw connections of flange and body components of the camera housings can be removed or untightened:
  - T08-VA1.x.K1.x: 6x M4\*0,7 cylinder head screw hexagon socket 10mm, 1.4404 A4-70 (DIN912/ ISO4762)
  - T08-VA1.x.K2.x: 5x M4\*0,7 cylinder head screw hexagon socket 25mm, 1.4404 A4-70 (DIN912/ ISO4762)
  - T08-VA2.x.K1.x: 8x M4\*0,7 cylinder head screw hexagon socket 12mm, 1.4404 A4-70 (DIN912/ ISO4762)
  - T08-VA2.x.K2.x: 7x M4\*0,7 cylinder head screw hexagon socket 30mm, 1.4404 A4-70 (DIN912/ ISO4762)
- Use adequate tools or the hex-wrench included in the delivery scope and pay attention not to lose the associated feather rings (DIN 127 A) (q.v. figure 10-7)
- Avoid skin or clothing contact with the screw threads as they dispose of LOCTITE ® 243™ (chemical basis: Dimethacry-latester). It is used to protect the screws from losing due to shocks, vibrations, but also for sealing purposes




Figure 10-7 Opening of the ExCam T08-VAx.x.x.x

- Pull out very carefully the lead flange in a straight manner (q.v. figure 10-7), ensuring that it does not tilt. Due to the created lower pressure, this might require some additional effort

The cylindrical clearance fit (H8f7 - DIN ISO 286) of the body as well as of the flange components must not be tilted as this runs the **risk of damaging the flame proof gap pre-venting the transmission of ignition (DIN EN 60079-1:2008)!**

Avoid skin or clothing contact at the cylindrical fit as it disposes of oleaginous fitting compound (MOLYKOTE P-40) to protect the surface for frictional corrosion and mechanical strain

- Attention: Installed components (camera module, optic, temperature controller etc.), which are fixed to the cable and supply flange have to be treated very carefully to avoid damages!
- Attention: When removing the flange, do not damage or pollute the Gylon sealing (style 3504 blue)!
- After completion of the measure, the housing has to be closed again immediately. Do not lock-in any foreign objects!
- For closing the housing, please follow, in reversed order, the steps described for the opening of the housing. Please observe the following warning instructions:



**Attention!**

**Make sure to completely insert the flange in order to guarantee the ignition protection type and the housing IP protection level**



**Attention!**

**Extensive tightening of the screw connection may damage the camera**



**Attention!**

**Beware not to damage the surface of bore hole and shaft (fit) at the flame proof gap preventing the transmission of ignition.**



**Attention!**

**Please make sure not to damage housing sealings and to keep them clean**



**Attention!**

**In case the flameproof joint has been damaged mechanically, the housing must not be used anymore!**



**Attention!**

**Do not lock-in any foreign objects inside the housing**

- Only the original screws as part of the delivery scope may be used. They have to be clean and intact. Demounted screw locks (washer spring DIN 127 A) have to be re-assembled
- The Gylon sealing must be intact and has to be reassembled according to the hole-pattern of the flange. There is no restriction regarding the installation direction of the sealing
- If, when closing the housing, it is noted that the surface of the flameproof joint is dirty or not lubricated sufficiently, please clean it with a clean cloth and suitable cleaning detergent. Afterwards, re-lubricate it with a suitable lubrication agent
- The screw connection of the flange and housing have to be tightened in crosswise sequence with a torque of **3 Nm**. Please avoid extensive tightening – this might lead to a torn screw resulting into damaging the housing's pressure resistance and / or ignition protection level

## 6.2.2 Type T08-TNXCD



**Attention! The pressure-tight dome housing type T08-TNXCD may only be opened when allowed by the user manual of the camera, e.g. for a manual adjustment, for the removal / exchange of the SD storage card, the exchange of the O-Ring sealing, hardware reset etc.**



**Attention! Observe all warnings on camera labels:**

**„WARNING – MAY NOT BE OPENED WHILE ENERGIZED“**

or

**„WARNING – MAY NOT BE OPENED IN HAZARD AREAS“**

**NOTE: Depending on the classification of the hazard area, a work permit/clearance has to be obtained. Prevent explosive atmospheres while assembling!**

The T08 ExCam Series may exclusively be opened due to functional aspects and when the applicable user manual explicitly allows it. For all other purposes, the explosion proof housing may only be opened and closed by authorized personnel of the company SAMCON Prozessleittechnik GmbH.

If, when looking through the transparent polycarbonate dome cupola a damage, irregularities, or alterations such as loose parts, discoloring, or liquid inclusion (not water condensation!) are visible inside the ExCam, SAMCON Prozessleittechnik GmbH has to check the camera.

The following has to be observed:

- Prior to opening the housing of the type T08-TNXCD it might be necessary to de-install the hood or other accessory
- Demount the housing from the wall mount bracket / chain links to allow an opening of the housing at a suitable location  
Attention: Connecting cables have to be carried along and must not be damaged / bent (bending radius) or have to de-connected from the Ex e terminal box or the Ex e / Ex d plug connector etc.!

- The housing must only be opened at the rear flange of the cable and supply flange. It is not allowed to remove the optic-adapter
- In order to open the housing, the body has to be fixed. The cover flange with the cable (pig tail) has to remain flexible (e.g. with screw clamps at the edge of a work bench)
- The first step is to loosen the stainless steel countersunk head screw with hexagon socket (DIN 7991) at the flange component (q.v. figure 10-8)



Figure 10-8 Disassembly of the countersunk head screw type T08-TNXCD

- Counterclockwise, unscrew the cover flange with fine thread (M18x1.5) (ISO-metric profile clockwise). It is suggested to equip the external M8x1.25 thread holes with screws, eyelets etc. in order to facilitate the rotary movement (q.v. figure 10-9). Attention: Also rotate the cable (pig tail) if necessary!
- Attention: Pull out very carefully and a very straight manner the cover flange with the multi-level mounting adapter, the electronics, and the PTZ module etc. to avoid tilting and through this damaging the installation parts!




Figure 10-9 Opening of the cover flange type T08-TNXCD

- The metric fine thread (M188x1.5/ larger 5 supporting thread holes / quality 6g) located at the flange as well as body component may not be damaged! **Danger through damaging the flame proof gap preventing the transmission of ignition (DIN EN 60079-1:2008)!**  
 Avoid skin or clothing contact at the cylindrical fit as it disposes of oleaginous fitting compound (MOLYKOTE P-40) to protect the surface for frictional corrosion and mechanical strain
- Attention: Installed components (camera module, temperature controller, pan and tilt drives, and mechanical parts etc.), which are fixed to the cable and supply flange have to be treated very carefully to avoid damages and the drifting of the optical axis!
- Attention: When removing the flange, do not damage or pollute the black O-Ring sealing (VMQ-Silikon, NBR-70 or Viton) (q.v. figure10-10)!



Figure 10-10 Position of the O-Ring sealing type T08-TNXCD

- After completion of the measures, the housing has to be closed again immediately. Do not lock-in any foreign objects!
- For closing the housing, please follow, in reversed order, the steps described for the opening of the housing. Please observe the following warning instructions:



**Attention!**

**Make sure to completely insert the flange in order to guarantee the ignition protection type and the housing IP protection level**



**Attention!**

**Tighten the flange by hand, there is no tightening torque defined**



**Attention!**

**Beware not to damage the surface of bore hole and shaft (fit) at the flame proof gap preventing the transmission of ignition.**



**Attention!**

**Make sure that the O-Ring seal of the housing fits properly into the groove and is neither damaged nor polluted**



**Attention!**

**In case the flameproof joint has been damaged mechanically, the housing must not be used anymore!**



**Attention!**

**Do not lock-in any foreign objects inside the housing**



**It is mandatory to reassemble the countersunk head screws with hexagon sockets (DIN 7991). The tightening torque of 2.5 Nm has to be observed**

## 6.3 Electrical Connection and Commissioning



**Attention!**

The electrical connection of the device may only be carried out by qualified personnel

The electrical connection and commissioning must be executed in accordance with national regulations by authorized personnel only.

**Please note the electrical connection specifications of the device user manual!**



**Attention!**

The housing of the ExCam® series must be earthed via the PA connection (earthing screw)



**Attention!**

The heating has to be fused externally

If the camera will have to be commissioned at temperatures below 0° C, it has to make sure that the camera is turned on time delayed. Before the camera is allowed to be used, the housing has to be heated up which can be realized via an external time relay.

Before commissioning the camera, the tests as indicated in the individual national regulations have to be executed. In addition, the correct functioning and installation of the equipment in accordance with this installation manual as well as with other regulations that apply, has to be ensured.

Improper installation and operation of the camera may lead to a loss of warranty!

**The functional commissioning of the applicable camera is described in the associated user manual.**

## 7 Maintenance/ Modification

**The applicable regulations for the maintenance and servicing of electrical devices in potentially explosive atmospheres must be followed.**

The necessary maintenance intervals depend on the operating condition and have to be individually determined by the user. Especially parts on which the type of protection depends are to be examined as part of the maintenance (e.g. sound condition of the casing, the seals and the cable entry points). Repair works should be carried out when the need for them is recognised during maintenance.

## 8 Reparation

Reparations must only be carried out with original parts of SAMCON Prozessleittechnik GmbH. Damaged pressure-resistant casing should be replaced completely. In case of doubt, send the part in question back to SAMCON Prozessleittechnik GmbH.

Reparations concerning the explosion protection must only be carried out in accordance with nationally applied regulations by SAMCON Prozessleittechnik GmbH or a qualified electrical technician authorised by SAMCON Prozessleittechnik GmbH.

Rebuilding of or alterations to the devices are not permitted.

## 9 Disposal/ Recycling

When disposing of the device, nationally applicable regulations must be observed.  
This Document is subject to alterations and additions.

## 10 Drawings

Equipment drawings can be found in the individual datasheets.  
DXF files, 3D models, drawings of accessories can be found at [www.samcon.eu](http://www.samcon.eu)  
For additional information, please contact us at support@samcon.eu

## 11 Certificates

### 11.1 EC – declaration of conformity

## EG/EU - Konformitätserklärung

EC/EU – Declaration of Conformity / CE/UE – Déclaration de Conformité

Das Produkt / L'appareil / Le produit



**SAMCON**  
Process & Industrial Gases

**Schillersstraße 17**  
**35102 Lohra-Altenvers**

erklärt, dass das hierunter beschriebene Produkt den Anforderungen nach folgenden Richtlinien entspricht, ganz besonders:

### ExCam™ T08...

geschildert im Zusammenhang mit:

Model Keys: T08-YAxxxxx-X-X-X-X

Model Keys: T08-EXACD-X-X-X-X

Gesamt:

Gesamt:

Ex II 3G Ex d IIC T4 Gb IP66

Ex II 2D Ex d IIC T4 Gb IP66

Wand:

Wand:

Ex II M2 Fx II MB

Ex II 2D Ex d IIB T4 Gb IP66

Montage:

Montage:

Ex II M2 Fx II MB

Optional und erreichbar über die Frontplatte sind folgende Varianten von allen Typen:

- [ ] - ohne Modulare Ex-Zubehör (Standard)
- [ ] - mit Modularem Ex-Zubehör (PCO-Boxe) 2009
- [ ] - mit Modularem Ex-Zubehör (PCO-Boxe)

- [ ] - ohne Modulare Ex-Zubehör (Standard)
- [ ] - mit Modularem Ex-Zubehör (PCO-Boxe)
- [ ] - mit Modularem Ex-Zubehör (PCO-Boxe)

Hersteller ist EG-Richtlinie und dessen Anhang 10 (Modell) für diese Konformitätserklärung zuständig.

### TÜV 14 ATEX 7639 X

Die hierin dargestellte ATEX-Konformitätserklärung ist gültig bis 10.04.2014, Normen oder Normenäquivalente: Zeichen der Gütekennzeichnung für die ATEX-Konformitätserklärung und die Richtlinie 2014/34/EU sowie die zugehörigen Anhangs-Dokumente und Dokumente zur Dokumentation der Konformitätserklärung.

ATEX Richtlinie/ATEX Directive/Directive ATEX	
Bl. 140721-PT08BAU	AEI/Exm030
ATEX-CE	ATEX-CE
WID 140721-11	ATEX/IECEx
94/9/CE	2014/34/EU
01/9/EC	2013/65/EU

Normen / Standards / Normen	
EN 60079-0	2012
EN 60079-1	2012
EN 60079-11	2012
EN 60079-15	2012
EN 60079-28	2009
EN 60079-71	2006 (Ang. 159/2011)



Dipl.-Ing. Steffen Seiber,  
Geschäftsführer

SAMCON Process & Industrial Gases  
Schillersstraße 17  
35102 Lohra-Altenvers  
www.samcon.de  
E-Mail: post@samcon.de

ExCam™ ATEX version, dated 10.04.2014

Doc-ID: 140721-PT08BAU-SS-Ex Installation Manual rev.04.docx

## 11.2 Manufacturer's declaration concerning the cable and cable entry points

# Herstellererklärung

*Declaration of manufacturer / Déclaration de fabricant*

Der Hersteller / The manufacturer / Le fabricant



**Schillerstraße 17  
35102 Lohra-Altenvers**

Erklärt in alleiniger Verantwortung, dass die verbindenden Kabel und Kabelleitungseinrichtungen für sein Produkt  
Zertifiziertes Maßnahmen verantwortlich, that Cable and Cable Islands for his product  
make sure that these components are certified as described in section 10 above and prove it.

## ExCam T08...

gekennzeichnet mit / marked with / marqué avec:

Modell-Kenns.: T08-VAnxx-x-X-X-X

Modell-Kenns.: T08-TAnxx-x-X-X-X

Dust:

Dust:

I 2D Ex tb IIIC T<sup>m</sup> Dc IP68

II 2D Ex tb IIIC T<sup>m</sup> Dc IP68

Watdmg:

Watdmg:

I M2 Ex tc II Mc

Optional and additional type of Protection markings for all Types:

- For models with [ ] flameproof connection
- For models with [ ] EEx connection
- For models with [ ] II

- For models with [ ] flameproof connection
- For models with [ ] EEx connection

Beschreibung: I E3 Baumusterprüfung & IECEx Zertifikat:  
certified by EC-type examination certificate & IECEx certificate  
mark of quality on Declaration of Type ATEX/IECEx

## TÜV 14 ATEX 7539X & IECEx TUR14.0026X

Die hier aufgeführten technischen Daten und Angaben basieren auf den vom Hersteller vorgelegten Dokumenten und sind nicht bindend.  
Subjected to the declaration is in accordance with the following standards or normative documents:

0001400101

Angewandte Regelwerke: ATEX Directive 2014/34/EU; IECEx Directive 01/01/2010

**DIN EN 60079-14:2014  
IEC 60079-14:2013**



Die Unterschrift ist von Steffen Seibert  
Dokumentenleiter bei SAMCON Gmbh, u.  
email: [seibert@samcon.eu](mailto:seibert@samcon.eu), d-DE  
Datum 20.01.2014 (Seibert-01-14)

Pl.-Ing. Steffen Seibert  
seibert@samcon.eu

Pl.-Ing. Steffen Seibert, der am 20.01.2014

Den. - 10 - IEC60079-14-EN+AIECEx-Konformitätszertifizierung 2014-01-14

### 11.3 EC-Type Examination Certificate

#### (1) EC TYPE-EXAMINATION CERTIFICATE



- (2) Equipment and Protective Systems intended for use in Potentially Explosive Atmosphere - Directive 94/9/EC
- (3) EC Type-Examination Certificate Number

**TÜV 14 ATEX 7539 X**

- (4) Equipment: ExCam Series T08
- (5) Manufacturer: SAMCON Prozessautotechnik GmbH
- (6) Address: Schillerstraße 17,  
D-95102 Lehrte-Altenvers

- (7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The TÜV Rheinland Zertifizierungsschule for ex-protected products of TÜV Rheinland Industrie Service GmbH, Notified Body No. 0035 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmosphere, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report 557/Ex539.00/14.

- (9) Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule of this certificate, has been assessed by reference to:

EN 60079-0: 2012    EN 60079-1: 2007    EN 60079-31:2009    EN 60079-28: 2007

except of the requirements, which are listed under item (18).

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type-Examination Certificate relates only to the design and specification for construction of the equipment or protective system. It does not cover the process for actual manufacture or supply of the equipment or protective system, for which further requirements of the directive are applicable.
- (12) The marking of the equipment shall include the following:

- I M2 Ex d I Mb
- II 2 G Ex d IIIC T6 Gb or Ex d IIIC T5 Gb
- II 2 G Ex d IIIB T6 Gb or Ex d IIIB T5 Gb
- II 2 D Ex tb IIIC T80 °C Db IP68 or II 2 D Ex tb IIIC T95 °C Db IP68

TÜV Rheinland-ExNB for explosion protected equipment

Cologne, 2014-07-29

Dipl.-Ing. Heinz Farka

This EC-Type-Examination Certificate without signature and stamp shall not be valid.  
This EC-Type-Examination Certificate may be consulted only without alteration. Changes or alterations are subject to approval by the  
TÜV Rheinland Notified Body of TÜV Rheinland Industrie Service GmbH, Am Grauen Stein 11-13, Köln  
Tel. +49 (0) 221 809-0 Fax. +49 (0) 221 809 111

[www.tuv.com](http://www.tuv.com)



(13)

Annex to

(14)

## EC-Type Examination Certificate TÜV 14 ATEX 7539 X

(15) Description of equipment

### 15.1 Equipment and type:

ExCam Series T08 VA1x : VA2x

### 15.2 Description

#### General product information

The ExCam Series Type 08 is an electrical device. It is certified according to ATEX and IECEx as a pressure-resistant camera system to be used in gas and dust explosive area II as well as in mines susceptible to firecamp.

At the front side, the camera systems dispose of a flange with a sight glass. On the rear side it is equipped with a flange which allows introducing ex-certified cable and cable glands or sealing plugs.

The cameras are certified to be used in ex-zones 1, 2, 21, 22 including the explosion groups IIC and IIB and group M2 resp. Mb.

The Ex-d housings are available in different steel qualities due to which the housing's resistance towards extreme environmental conditions (sea water corrosion, high acid environments etc.) is additionally extended.

Within the pressure-resistant enclosure, various camera modules and lenses reflecting different technical specifications. Accessory components such as PTC heating elements, miniature fans, NIR LED, lighting devices, mechanical components and clamps made of aluminum are optional. Criteria for selecting the camera module are, for example, transmission technology (digital or analog), control functions (IR-cut filter, iris, focus), light sensitivity, angle of view, object distance, resolution, optical zoom range, frame rate, or transmission delay. Thermal imaging applications are possible as well.

### 15.3 Technical Data

Typ T08 VA1.2      supply voltage: 12...80V DC  
 Typ T08 VA2.2      supply voltage: 12...80V DC or 230V ( 50/60 Hz) AC

Maximum input power:

	T6			
	Tamb	40°C	50°C	60°C
VA1.2.xx	18,2 W	13,6 W	9,1 W	4,5 W
VA2.2.xx	25,0 W	18,8 W	12,5 W	6,3 W

	T5				
	Tamb	40°C	50°C	60°C	70°C
VA1.2.xx	20,5 W	15,9 W	11,4 W	6,8 W	4,5 W
VA2.2.xx	28,1 W	21,9 W	15,6 W	9,4 W	6,3 W

Types T08 VA1.1 and VA2.1 are not included.

The ambient temperature range is: - 80 °C <= Ta <= + 75°C

(16) Test-Report No. 557/Ex639.00/14

(17) Special Conditions for safe use

The connecting cable needs a minimum length of 1 meter. The connecting cable has to be laid shielded.

External heat and/or cooling sources have to be taken into account during the setting up.  
 The permissible temperature range has to be observed.

When using the ExCam in the mining sector with a "high" risk of mechanical danger, it is mandatory to protect the transparent parts (Glas) of the device.

The housing of the ExCamB series must be earthed via the PA connection.

The heating has to be fused externally.

In case of repair of the flamepath forming parts see manufacturer information.

All used Cable glands and plugs have to be certified.

This EC-Type-Examination-Certificate without signature and stamp shall not be valid.  
 This EC-Type-Examination Certificate may be circulated only within the above stated. Persons or authorities are subject to approval by the  
 TÜV Rheinland Notified Body of TÜV Rheinland Industrie Service GmbH, Am Grauen Stein 51105 Köln  
 Tel. +49 (0) 221 808-0, Fax. +49 (0) 221 808-114

(16) **Basic Safety and Health Requirements**

Covered by above mentioned standard

TÜV Rheinland ExNB für explosion protected equipment

Cologne, 2014-07-29



## 1<sup>st</sup> Supplement

to

### EC - Type Examination Certificate

### TÜV 14 ATEX 7539 X



Device: ExCam Series T08  
 Manufacturer: SAMCON Prozessorteknologi GmbH  
 Address: Schillerstraße 17,  
 D-35182 Lohne-Altenvers

Description of supplements and modifications:

Adding the Model T08-TNXCD... (BARTEC TECH-NOR AS) only for Gas and Dust.  
 Adding the Model T08-WAx1... (SAMCON GmbH)  
 Adding the Model T08-WAxX... (SAMCON GmbH) (\* = housing protective coating))

(1G) The following modifications are valid for this 1<sup>st</sup> Supplement

Standard basis

EN 60079-0:2012, EN 60079-1:2007, EN 60079-11:2012  
 EN 60079-15:2009, EN 60079-28:2007 (Addition 1:2014-09)  
 EN 60079-31:2008

Code for type of protection

Gas:

II 2 G Ex d IIC T6 Gb      II 2 G Ex d IIIB T6 Gb

Dust:

II 2 D Ex tb IIIC T80°C Db IP65      II 2 D Ex tb IIIC T90°C Db IP65

MB:

II 1 M2 Ex d I Mb

Optional and additional Type of Protection markings for all Types:

- [a] = for models with explosive certified [a] intrinsically safe circuits
- [b] = for models with explosive certified [b] intrinsically safe circuits
- [op. a] = for models with explosive certified [op. a] "DC connections"
- [op. c] = for models with explosive certified [op. c] "DC Connections"
- [mb] = for models with explosive certified [mb] Barrier

This 1<sup>st</sup> Supplement to the EC - Type Examination Certificate version signatures and names shall not be valid.  
 The signature below the EC - Type Examination Certificate is only valid when combined with the original examination certificate issued by the following  
 TÜV Rheinland Validated Code of TÜV Rheinland Institute Service Center, Am Deister 50, D-31108 Kassel  
 Tel.: +49 (0)521 364-0, Fax: +49 (0)521 366-114

Page 1 of 5 of the Supplement to the examination certificate

[www.tuv.com](http://www.tuv.com)



### 15.1 Equipment and Type

ExCom Series T08-VA...  
ExCom Series T08-TNXCD...

### 15.2 Description

The announcement relates to the Equipment and Types:

ExCom Series T08-VA...  
ExCom Series T08-TNXCD...

### 15.3 Technical Data

#### Supply Voltage:

Type: T08-VA... 12 ... 80V DC or 240V (50/60 Hz) AC  
Type: T08-TNXCD... 12 ... 60V DC or 240V (50/60 Hz) AC

#### Maximum Input Power:

Type: T08-VA...:

T08-	T <sub>08</sub> (85°C - 6K)					T <sub>08</sub> (100°C - 16K)				
	-40°C	-20°C	0°C	20°C	40°C	-50°C	-30°C	0°C	20°C	40°C
VA1.1.x.x	17.4 W	13.0 W	8.7 W	4.3 W	19.8 W	15.2 W	10.9 W	6.5 W	4.3 W	
VA1.1.x.x* (coated)	19.0 W	14.5 W	9.5 W	4.8 W	21.4 W	16.7 W	11.3 W	7.1 W	4.8 W	
VA1.2.x.x	18.2 W	13.8 W	9.1 W	4.5 W	20.5 W	15.8 W	11.4 W	6.8 W	4.5 W	
VA1.2.x.x* (coated)	21.1 W	15.8 W	10.5 W	5.3 W	23.7 W	18.4 W	13.2 W	7.9 W	5.3 W	
VA2.1.x.x	22.2 W	18.7 W	11.1 W	6.8 W	25.0 W	19.4 W	13.9 W	8.3 W	5.8 W	
VA2.1.x.x* (coated)	26.0 W	16.5 W	12.5 W	6.8 W	28.1 W	21.8 W	16.0 W	9.4 W	6.3 W	
VA2.2.x.x	35.0 W	18.5 W	12.5 W	6.2 W	38.1 W	21.8 W	16.0 W	9.2 W	6.3 W	
VA2.2.x.x* (coated)	38.7 W	20.2 W	13.3 W	6.7 W	40.0 W	23.3 W	18.7 W	10.0 W	6.7 W	

Type: T08-TNXCD...

T08-	T <sub>08</sub> (95°C - 6K)				
	-40°C	-20°C	0°C	20°C	40°C
TNXCD	57.1 W	50.0 W	42.9 W	35.7 W	28.8 W

This declaration is issued by TÜV Rheinland Group, that the product has been tested according to the following test specification:  
This equipment to the EC-Type Examination Certificate may be marketed only without alterations. Details of alterations are subject to approval by  
TÜV Rheinland Quality Council of TÜV Rheinland Quality Council, Am Grasen 20, D-5110 Köln  
Tel.: +49(0)211/918011, Fax: +49(0)211/911133

Page 2 of 2 of the Supplement to TÜV 14 ATEX 750 X

**Ambient Temperature Range:**

TBD-VA	-80°C ≤ T <sub>d</sub> ≤ +75°C
TBD-TNKC03X...	For Gas: -80°C ≤ T <sub>d</sub> ≤ +80°C For Dust: -20°C ... +60°C (Steel) with Viton O-Ring -30°C ... +60°C (Steel) with NBR 70 O-Ring -50°C ... +50°C (Steel) with VMQ-Silicon O-Ring

(16) Test Report No. 557/Lx/SSB/01/14

Parts of the device, which already fulfill the requirements for the category, were not approved and assessed by TÜV Rheinland Industrie Service.

The applicability and assembly of mechanical and electrical parts and components were assessed and approved by TÜV Rheinland Industrie Service with respect to the requirements of explosion protection.

(17) Special conditions for safe use

The original certificate has to be observed.

(18) Basic Safety and Health Requirements

Covered by mentioned standards in the original certificate.

TÜV Rheinland ExnB for explosion protected equipment

Cologne, 2015-03-31



This Test Report is valid for the EC-Type Examination Certificate issued by SAMCON Process & Technik GmbH.  
This supplement to the EC-Type Examination Certificate may be circulated only without alteration. Circulation or alteration is subject to approval by  
TÜV Rheinland Industrie Service of TÜV Rheinland Industrie Service GmbH, Am Gänsemarkt 112, 40211 Düsseldorf.  
Tel. +49 211 98 00 6000, Fax: +49 211 98 00 114

Page 3 of 3 of the Supplement to TÜV 94 ATEx 250/2

## 11.4 IECEx Certificate of Conformity

		<b>IECEx Certificate of Conformity</b>
INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres		
For more information about the IECEx Scheme visit <a href="http://www.iecex.com">www.iecex.com</a>		
Certificate No.:	IECEx TÜV 14.00289	Issue No. 0
Status:	Current	Cert. Body history: Issue No. 0 (2014-07-28)
Date of Issue:	2014-07-28	Page 1 of 3
Applicant:	SAMCON Process- und Technik GmbH Schillerstraße 17 D-55102 Ludwigshafen Germany	
Electrical Apparatus: Optional accessory:	ExCam Series T08	
Type of Protection:	Rid and Exit	
Marking:	Ex d I MB, Ex d IIC T85°C Db, Ex d IIIC T5 Gb, Ex d II T5 Gb, Ex d II T5 Gb Ex tb IIC T85°C Db, Ex tb IIIC T5 Gb	
Approved for issue on behalf of the IECEx Certification Body:	Hans Falck	
Position:	Deputy Head of ExCB	
Signature: (for printed version)	 <u>2014-07-19</u>	
Date:		
<p>1. This certificate and schedule may only be reproduced in full. 2. This certificate is not transferable and remains the property of the issuing body. 3. The status and authenticity of this certificate may be verified by visiting the Official IECEx Website.</p>		
Certificate issued by:		
TÜV Rheinland Industrie Service GmbH Am Grassen Stein 51105 Cologne Germany		
		



## IECEx Certificate of Conformity

Certificate No:

IECEx TUR 14.0002EX

Issue 101 R

Date of Issue:

2014-07-29

Page 2 of 3

Manufacturer:

SAMCON Process & Technik GmbH  
Scheibenstraße 17  
D-35132 Lohra-Altenau  
GermanyAdditional Manufacturing  
Location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard(s) below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx System Rules, IECEx G2 and Operational Documents as amended.

**STANDARDS:**

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition 6.3	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2007-04 Edition 8	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosure "M"
IEC 60079-28 : 2006-03 Edition 1	Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
IEC 60079-31 : 2008 Edition 1	Explosive atmospheres - Part 31: Equipment during lightning protection by enclosure T

The Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

**TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

CERTIEC/TUR 14.0002/00

Quality Assessment Report:

CE/95/52/RTA/0009/00



## IECEx Certificate of Conformity

Certificate No:

IECEx TUR 14.0020X

Issue No: 0

Date of Issue:

2014-07-29

Page 3 of 3

### Schedule

**EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The ExCam Series Type US is an electrical device. It is certified according to ATEX and IECEx as a pressure-resistant camera system to be used in gas and dust explosive areas as well as in mines susceptible to fire/explosion. At the front side, the camera systems dispose of a flange with a slight glass, on the rear side it is equipped with a flange which allows introducing ex-certified cable and cable glands or sealing plug. The cameras are certified to be used in ex-zones 1, 2, 21, 22 including the explosion groups II C and II D and group I (exp. Min.). The Front housings are available in different steel qualities due to which the housing's resistance towards extreme environmental conditions (see water corrosion, high acid environments etc.) is additionally extended. Within the pressure-resistant enclosure, various camera modules and lenses featuring different technical specifications. Accessory components such as PTC heating elements, miniature fans, M-R LED, lighting devices, mechanical components and stamps made of aluminum are optional. Criteria for selecting the camera module are, for example, transmission technology (digital or analog), control functions (IR cut filter, Mic, Focus), light sensitivity, angle of view, object distance, resolution, optical zoom range, frame rate, or transmission delay. Thermal imaging applications are possible as well.

**CONDITIONS OF CERTIFICATION: YES as shown below:**

1. The connecting cable needs a minimum length of 1 meter. The connecting cable has to be laid shielded.
2. External heat and/or cooling instances have to be taken into account during the setting up. The permissible temperature range has to be observed.
3. When using the ExCam in the mining sector with a "high" risk of mechanical danger, it is mandatory to protect the glass parts of this device.
4. The housing of the ExCam0 series must be earthed via the PA connection.
5. The heating has to be fused externally.
6. In case of repair of the Non-explosion forming parts see manufacturers information.
7. All used Cable glands and plugs have to be certified.



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

For rules and standards of the IECEx Scheme, visit [www.iecex.com](http://www.iecex.com)

Unit Index No.	IECEx TU/14.0025A	Issue No. 1	Doc. Identification: IECEx No. 1102310 S-31 Issue No. 310212-7-296
Review	Current		
Date of issue:	2016-02-01	Page 1 of 9	
Applicant:	SAMCON Process & Technik GmbH Seelstrasse 17 D-5112 Lohrsdorf-Hamm Germany		
Electrical Protection Options/accordance:	Exd I Mb, Ex d IIC T6 Ga, Ex d IIIC T5 Ga, Ex d IIB T85°C, Ex d III T5 Ga, Ex tb IIIC T85°C Db Ex tb IIIC T85°C Db		
Type of Protection:	Ex d and Ex t		
Wiring:	Ex d I Mb, Ex d IIC T6 Ga, Ex d IIIC T5 Ga, Ex d IIB T85°C, Ex d III T5 Ga, Ex tb IIIC T85°C Db Ex tb IIIC T85°C Db		
Approved for issue on behalf of the IECEx Certification Body:	Dipl.-Ing. Kasparika Chai		
Reviewer:	Head of Certification Policy		
Signature: <small>(Handwritten signature)</small>			
Date:	<u>2015-02-01</u>		

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The status and validity of this certificate may be verified by visiting the Official IECEx Website.

Conformity issued by:

TÜV Rheinland Industrie Service GmbH  
Am Deutschen Platz  
51165 Cologne  
Germany





## IECEx Certificate of Conformity

Certificate No:	IECEx TUR 14.0025K	
Date of issue:	2015-03-01	Issue No: 1
Page 2 of 5		
Manufacturer:	SAMCON Process & Technik GmbH Südlochstrasse 17 D-5110 Lohr Amtsamt Germany	
<b>Additional manufacturing location(s):</b>		
This certificate is issued to verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard IEC 60079-0 and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx QC and Operational Documents as appended.		
<b>STANDARDS:</b> The standard appears and any acceptable variations to it specified in the schedule of this certificate and the identified IECEx RICs, was found to comply with the following standards:		
IEC 60079-0 : 2011 Edition 2.0	Explosive atmospheres - Part 0: General requirements	
IEC 60079-1 : 2007-04 Edition 2	Explosive atmospheres - Part 1: Equipment protection by limited ignition energy "M"	
IEC 60079-28 : 2009-09 Edition 1	Explosive atmospheres - Part 28: Protection of equipment and instrumentation systems using intrinsic safety "i"	
IEC 60079-31 : 2008 Edition 1	Explosive atmospheres - Part 31: Equipment classification protection by enclosure "T"	
This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.		
<b>TEST &amp; ASSESSMENT REPORTS:</b> A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in		
Test Report:	CE/TUR/SD/TUR/14.0025/01	CE/TUR/SD/TUR/14.0025/1
Quality assessment Report:	CE/RUS-QAR/14.0025/01	



## IECEx Certificate of Conformity

Serial code No.:

IECEx UK 14.27885

Date of issue:

2015-03-31

Issue No.: 1

Page 2 of 5

### Schedule

**EQUIPMENT:***Equipment and systems covered by the certificate are as follows:*

The ExCam Series Type 00 is an electrical device. It is certified according to ATEX and IECEx as a pressure-vessel intact cameras system to be used in gas and dust explosive areas as well as in other explosive hazard grouping. At the front side, the camera system dispose of a flange with a cooling pipe. On the rear side it is equipped with a flange which allows mounting of external optics and cooling source or cooling pipe. Therefore it is qualified to be used in zones 1, 2, 21, 22 (including the explosion groups IIIC and IIIIC) and group I (exp. Mb). The Field Flanges are available in different sizes due the distance within the housing is resistance towards adverse environmental conditions (pneumatic connection, high cold ambient temp., etc.) is not formally evidenced.

Within the pressure-vessel-intact cameras, various camera modules are taken reflecting different technical specifications. Auxiliary components such as PTC heating elements, minimum bias, IR LED, lighting source, mechanical output and cable clamp made of aluminum are optional. Options for adapting the camera module and for control/transmission technology (digital or analog, contact, read out) (IP67 like, etc., local), programmable, cycle of non-object detection, resolution, optical zoom range, frame rate, or transmission delay. Thermal imaging applications are available as well.

**CONDITIONS OF CERTIFICATION: YCS as shown below:**

1. The connecting cable needs a minimum length of 1 m/meter. The connecting cable has to be kink shielded.
2. External heat sink and/or cooling source have to be taken into account during dimensioning. The permissible temperature has to be observed.
3. When using the ExCam in the rotating version with a height risk of mechanical danger, it is mandatory to prevent the plain parts of the device.
4. The housing of the ExCam Series must be earthed via the IP connection.
5. The sealing has to be tested internally.
6. In case of usage of the ExCam with cooling pipe, the connection has to be done.
7. A fused safety switch and plug have to be certified.



## IECEx Certificate of Conformity

Certificate No.: IECEx T08 14.0002X

Date of Issue: 23/04/2014

Issue No. 1

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

In accordance of the certified empty enclosure IECEx now includes RaR<sup>®</sup> Ex add-on for Day and Night. Type T08/Ex II 1c IIC T<sub>d</sub>(nA) and T4c II 1c IIC T<sub>d</sub>(nA) are now included.

#### Product Information:

T08\_250x220

-40°C ... +60°C (T<sub>d</sub>(nA))

T08\_150x220 (nA Day/Night)

-40°C ... +60°C (T<sub>d</sub>(nA))

T08\_150x220 (nA Day/Night) 20 °C ... +60 °C (T<sub>d</sub>(nA))

Type: T08 UL: nA	T08_250x220 (T <sub>d</sub> (nA))				T08_150x220 (T <sub>d</sub> (nA))			
	T <sub>d</sub> (nA)	-40°C	+20°C	+60°C	T <sub>d</sub> (nA)	-40°C	+20°C	+60°C
VDE/CE	250W	0.1W	1.1W	3.9W	151W	0.1W	1.1W	3.9W
VDE/CE marked	250W	0.1W	1.1W	3.9W	781W	0.1W	1.1W	3.9W
EN/CE	250W	0.1W	1.1W	3.9W	481W	0.1W	1.1W	3.9W
EN/CE marked	250W	0.1W	1.1W	3.9W	400W	0.1W	1.1W	3.9W



## IECEx Certificate of Conformity

Certifcate No:

PCRYT.IR.14.15560

Date of issue:

2015-03-24

Issue No.: 1

Page 5 of 5

## (Additional Information)

Type: T86	T86(IEC-86)				
	T86(IEC-86)				
	40°C	45°C	50°C	55°C	60°C
VAL000	45.1 W	43.9 W	42.9 W	42.9 W	42.9 W

Type: T86 VA-2706	T86(IEC-86)				T86(IEC-86)				
	T86(IEC-86)				T86(IEC-86)				
	40°C	45°C	50°C	55°C	40°C	45°C	50°C	55°C	60°C
VAL000	13.9 W	13.9 W	13.9 W	13.9 W	53.9 W	53.9 W	53.9 W	53.9 W	4.4 W
VAL001 Knew0	15.5 W	14.2 W	13.9 W	13.9 W	51.4 W	50.7 W	51.7 W	51.9 W	4.5 W
VAL002	16.2 W	13.8 W	13.9 W	13.9 W	50.2 W	50.9 W	51.4 W	51.9 W	4.5 W
VAL003 Knew0	21.7 W	15.9 W	15.9 W	15.9 W	55.1 W	56.7 W	56.2 W	56.9 W	5.1 W

## 11.5 EAC-Ex Certification

**ГАМБИЕННЫЙ СОЮЗ**

**СЕРТИФИКАТ СООТВЕТСТВИЯ**

№ ИЧ: RU C-DE.M1062.B.01921

Серия: 211 К № 0274053

**ОРГАН ПО СЕРТИФИКАЦИИ** Общество с ограниченной ответственностью «ПРОММАШ ТССТ». Место нахождения: 115114, Российская Федерация, город Москва, Борисовский проезд, дом 11, помещение 60. Фактический адрес: 115114, Российская Федерация, город Москва, Борисовский проезд, дом 11, помещение 60. Телефон: +7 (495) 775-48-45, факс: +7 (495) 775-48-45, адрес электронной почты: info@prommash.ru. Адресная регистрация регистрационный № РОСС ХЛ.0001.11 МК02 выдан 01.12.2014 года Федором Евгеньевичем Бородинским

**ЗАВИДРИТЕЛЬ** Общество с ограниченной ответственностью «Группа компаний «Сибспецтехэкспорт». Основной государственный регистрационный номер: 114547155374  
Место нахождения: 630015, Российская Федерация, город Новосибирск, Первый Красноярский, дом 3  
Фактический адрес: 630015, Российская Федерация, губерния Новосибирская, город Новосибирск, Первый Красноярский, дом 3  
Телефон: +7 3832461566, факс: +7 3832461566, адрес электронной почты: info@spetek.com

**ИЗГОТОВИТЕЛЬ** «SAMCON Processleitechnik GmbH».  
Место нахождения: Германия, Schillerstraße 17 D-35102 Lohra-Altenau  
Фактический адрес: Германия, Schillerstraße 17 D-35102 Lohra-Altenau.

**ПРОДУКЦИЯ** Взрывозащищенные камеры EX-Suit серии Т08  
Оборудование выпускается по технической документации разработанной для работы во взрывоопасных средах в соответствии с требованиями технического регламента ТР ТС 012/2011  
Маркировка взрывозащищены пригодна к применению (бланки №№ 0208292, 0208293, 0208294)  
Серийный выпуск

**КОД ТН ВЭД ТС**: 8525 80 190 0

**СООТВЕТСТВУЕТ ТРЕБОВАНИЯМ** Технического регламента Таможенного союза  
**ТР ТС 012/2011 "О безопасности оборудования для работы во взрывоопасных средах"**

**СЕРТИФИКАТ ВЫДАН НА ОСНОВАНИИ**

- акта о результатах анализа состояния производства «SAMCON Processleitechnik GmbH» № 02517АП от 15.04.2014 года;
- протокола испытаний № 241-2015-04 от 30.04.2015 года. Общество с ограниченной  
ответственностью «Центр научных исследований, испытаний и сертификации», Аттестат  
№ ИСОУ Р.У.0001.21.АВ67, срок действия до 21.07.2016 года.

**ДОПОЛНИТЕЛЬНАЯ ИНФОРМАЦИЯ**  
Специальные требования к условиям хранения не предусмотрены.  
Единий знак обращения производителя на рынке государственных Таможенного союза  
запасников и сопутствующих к ТР ТС 012/2011.

<b>СРОК ДЕЙСТВИЯ</b>	30.04.2015	по	29.04.2029	<b>ВКЛЮЧИТАЛЬНО</b>
М.П.				А.П. Филатов
				А.В. Ивочкин
				Исполнитель

Установка (руководитель подразделения по сертификации)  
декларант (эксперт-оценщик)  
(эксперт по вопросам качества)

**ГАМОЖЕННЫЙ СОЮЗ**
**ПРИЛОЖЕНИЕ**

RU C-ДЕМЮ62.В.01921

К СЕРТИФИКАТУ СООТВЕТСТВИЯ № ТС

Серия RU № 0206292

**1. Взрывозащищенные камеры EXSam серии Т08.**

Сертификат соответствия распространяется на взрывозащищенные камеры EXSam типов Т08 VA 1.x, Т08 VA 2.x, Т08-1NXLQ, Т08 УЛхх\* (\* - корпус с защитным покрытием).

**2. Описание оборудования и средства взрывозащиты**

Взрывозащищенные камеры EXSam предназначены для видеонаблюдения в подземных карбонатных пещерах, рудниках и их изымающих структурах, опасных по рудничному газу и/или горючей пыли, в соответствии с приведенной маркировкой взрывозащиты.

Корпуса камер выполнены из нержавеющей стали.

На лицевой стороне корпуса установлено смотровое стекло, на задней части камеры установлены сертифицированные зажимные винты и заглушки.

Электрические параметры:

Напряжение питания: 60 В постоянного тока или 240 В (50/60 Гц) переменного тока.

Максимальная выходная мощность:

Модель Т08 УЛ:

T08	T6 [85°C]				T5 [100°C]			
	40°C	50°C	60°C	70°C	40°C	50°C	60°C	70°C
УА1.1.хх	17,4 Вт	13,0 Вт	8,7 Вт	4,3 Вт	19,6 Вт	15,2 Вт	10,5 Вт	6,5 Вт
УА1.1.хх * (с покрытием)	19,0 Вт	14,3 Вт	9,5 Вт	4,8 Вт	21,4 Вт	16,7 Вт	11,9 Вт	7,1 Вт
УА1.2.хх	16,2 Вт	13,6 Вт	9,1 Вт	4,5 Вт	20,5 Вт	15,9 Вт	11,4 Вт	6,8 Вт
УА1.2.хх * (с покрытием)	21,1 Вт	15,4 Вт	10,5 Вт	5,3 Вт	23,7 Вт	18,4 Вт	13,2 Вт	7,9 Вт



Государственное (национальное  
или иное) агентство по сертификации

Эксперт (эксперт-аудитор)  
(эксперт (эксперт-аудитор))

А.П. Филатов

должность: начальник

А.В. Ивочкин

должность: инженер

**ГАМОЖЕННЫЙ СОЮЗ**
**ПРИЛОЖЕНИЕ**

К СЕРТИФИКАТУ СООТВЕТСТВИЯ № ГС:

Серия RU № 0208298

VAD 1.x.s	22,2 Вт	16,7 Вт	11,1 Вт	5,6 Вт	25,0 Вт	19,4 Вт	13,9 Вт	8,1 Вт	5,6 Вт
VAD 1.x.s [спецификация]	25,0 Вт	18,8 Вт	12,5 Вт	6,3 Вт	28,1 Вт	21,2 Вт	15,6 Вт	9,4 Вт	6,3 Вт
VAD 2.x.s	25,0 Вт	18,8 Вт	12,5 Вт	6,3 Вт	28,1 Вт	21,3 Вт	15,6 Вт	9,4 Вт	6,3 Вт
VAD 2.x.s [спецификация]	26,7 Вт	20,0 Вт	13,8 Вт	6,7 Вт	30,0 Вт	23,3 Вт	16,7 Вт	10,0 Вт	6,7 Вт
Модель Т08-TNХСД:	T <sub>0</sub> (85°C)								
	T <sub>ак</sub>								
T08	40°C	45°C	50°C	55°C	60°C				
TNХСД	37,1 Вт	50,0 Вт	47,9 Вт	55,7 Вт	58,8 Вт				

Степень защиты оболочки не ниже IP67/IP68 по ГОСТ 14254-96.

Диапазон рабочей температуры:

 T08-VA: -60°C ≤ T<sub>раб</sub> ≤ +75°C

 T08-TNХСД: T<sub>ак</sub> -50°C ≤ T<sub>раб</sub> ≤ +60°C

 План: -30 °C ... +60 °C (T<sub>ак</sub>) / уплотнительные кольца Viton O-Ring

 -30 °C ... +60 °C (T<sub>раб</sub>) / уплотнительные кольца NBR 70 O-Ring

 ... -50 °C ... +60 °C (T<sub>ак</sub>) / уплотнительные кольца VMQ-Silicon O-Ring

Взрывобезопасность камеры обеспечивается выполнением требований ТР ТС 012/2011 к требованиям на взрывостопорящий вид взрывозащиты.

Данный сертификат удостоверяет соответствие требованиям взрывобезопасности ТР ТС 012/2011 и не распространяется на любые другие виды опасности при испытании камеры.

3. Взрывозащищенные камеры ЕХСам серии Т08 соответствует требованиям:

ТР ТС 012/2011

Технический регламент Таможенного союза «О безопасности оборудования для работы во взрывоопасных средах»;

ГОСТ Р МЭК 60079-0-2011

Взрывозащищенные среды. Часть 0. Общие требования;

ГОСТ IEC 60079-1-2011

Часть 1. Оборудование с видом взрывозащиты взрывонепроницаемые оболочки "d".

ГОСТ Р МЭК 60079-31-2010

Часть 31. Оборудование с видом взрывозащиты от воспламенения пыли и в.


 Руководство (техническое  
задание) групп по сертификации

 Заявка (эксперт-аналитик)  
(эксперт-эксперт-аналитик)

А.П. Филимонов

 Инженер-аналитик  
А.П. Илюхин

**ТАМОЖЕННЫЙ СВИД****ПРИЛОЖЕНИЕ**

RU C-DE.M1062.8.01921

К СЕРТИФИКАТУ СООТВЕТСТВИЯ № РС

Серия RL № 0208294

**4. Маркировка взрывозащиты**

Ex d IIC T6/T5 Gb или Ex d IIIC T6/T5 Gb

-60°C ≤ T<sub>d</sub> ≤ +75°C

Ex tb IIC T80°C Db IP68 или Ex tb IIIC T95°C Db IP68

Ex Lx d I Mb

Маркировка специальным знаком взрывобезопасности **Ex** производится в соответствии с ТР ТС 012-2011.**5. Специальные условия применения**

Знак «Ex» и маркировка взрывозащиты пишут на особые условия их безопасного применения, заключающиеся в следующем:

- корпус должен быть герметичен, через герметичный моком РА;
- при электропитании должны учитываться все виды источников тепла или охлаждения;
- при использовании EXSam в горнодобывающей промышленности с большим количеством механических конструкций, должна быть предусмотрена защита прозрачной части устройства;
- используются только сертифицированные кабельные шланги и заглушки.



Руководитель (исполнительное лицо) органа по сертификации

Эксперт (эксперт-аудитор)  
(эксперт-испытатель)

A.I. Филатов

руководитель

А.В. Ивочкин

руководитель



**SAMCON**  
Fertigungstechnik GmbH

Schillerstrasse 17, 35102 Lohra-Altenvers  
[www.samcon.eu](http://www.samcon.eu), [info@samcon.eu](mailto:info@samcon.eu)  
fon: +49 6426 9231-0, fax: - 31